

Work Order List - Wide

WO Query: Trgt Dt from 5/1/2008 to 5/30/2008

WO No	Maintain Task Summary	Trgt Dt	Cfman	Location	WO Type	Status	Sts Dt	Priority	Downtime	
									Proj	Actl
2280	HPTestor 25 HP1740A Oscilloscope - voltage, amp, resistance calibration	5/21/2008	(none/mult)	\D2\B1\Cal Lab (45)	cal	cls	5/20/2008	hi	00:00	00:00
2282	HPTestor 30 HP1740A Oscilloscope - voltage, amp, resistance calibration	5/21/2008	Betty B	\D2\B1\Cal Lab (45)	cal	cls	5/21/2008	hi	00:00	00:00
2322	Boiler 1 Boiler 180 day PM	5/17/2008	AG	\D2\B2\F1\R112 (12)	pm	cls	5/18/2008	med	00:00	00:00
2326	Boiler 2 Boiler 180 day PM	5/17/2008	(none/mult)	\D2\B2\F1\R112 (12)	pm	cls	5/19/2008	med	00:00	00:00
2330	Boiler 3 Boiler 180 day PM	5/23/2008	Betty B	\D2\B1\Roof (Roof)	pm	cls	5/26/2008	med	00:00	00:00
2334	Flow Meter 1 Flow Meter Calibration	5/18/2008	MV	\D2\B2\F1\Assembly 1 (Assy1)	pm	cls	5/18/2008	med	00:00	00:00
2340	Conveyer 1 Conveyer 1 Month PM	5/28/2008	JG	\D2\B2\Y1 (9)	pm	sch	5/23/2008	med	00:00	00:00
2343	Loc: \D2\B1 (5) Lawn Mowing	5/4/2008	MV	\D2\B1 (5)	rtne	cls	5/4/2008	med	00:00	00:00
2344	Loc: \D2\B1 (5) Lawn Mowing	5/18/2008	JG	\D2\B1 (5)	rtne	cls	5/19/2008	med	00:00	00:00
2347	CB602 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/1/2008	(none/mult)	\TNP\Clifton (41)	serv	cls	5/2/2008	hi	00:00	00:00
2350	CB603 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/8/2008	(none/mult)	\TNP\Clifton (41)	serv	cls	5/9/2008	hi	00:00	00:00
2353	CB604 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/15/2008	JB	\TNP\Clifton (41)	serv	cls	5/16/2008	hi	00:00	00:00
2356	CB501 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/15/2008	JC	\TNP\Pecos (40)	serv	cls	5/16/2008	hi	00:00	00:00
2360	CB401 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/22/2008	(none/mult)	\TNP\Silver City (39)	serv	cls	5/24/2008	hi	00:00	00:00
2363	CB801 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/6/2008	(none/mult)	\TNP\Texas City (43)	serv	cls	5/7/2008	hi	00:00	00:00
2367	CB703 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/22/2008	(none/mult)	\TNP\Ft. Worth (42)	serv	cls	5/24/2008	hi	00:00	00:00
2371	CB702 Major Maintenance triggered by 5 fault interrupts or 3 year schedule	5/22/2008	JH	\TNP\Ft. Worth (42)	serv	cls	5/24/2008	hi	00:00	00:00