

Maintenance History Summary - by Equipment

WO Query: Status 'Closed', Sts Dt from 1/1/2008 to 4/30/2008

Closed Date	Sasmdl	WO - Task	WO Type	Init Type	Fail Rsn	Task Description	From Proc?	Dntm	Lbr hr	Lbr Cost	Parts Cost	Other Cost	Total Cost	
Equipment:		CB703 - Circuit Breaker 703					Eqmt Cls/Type:		Cbreaker / TNP2					
Location:		\TNP\Ft. Worth (42)					Serial No:		7823478342673427843287					
1/25/2008		2297 - 1	serv	sch		Major Maintenance triggered by 5 fault interrupts or 3 year schedule	Y	00:00	05:30	\$247.50	\$0.00	\$0.00	\$247.50	
2/23/2008		2364 - 1	serv	sch		Major Maintenance triggered by 5 fault interrupts or 3 year schedule	Y	00:00	06:00	\$270.00	\$4.00	\$0.00	\$274.00	
4/24/2008		2366 - 1	serv	sch		Major Maintenance triggered by 5 fault interrupts or 3 year schedule	Y	00:00	05:30	\$0.00	\$0.00	\$0.00	\$0.00	
* Total for Eqmt:		CB703			WO Cnt:	3		00:00	17:00	\$517.50	\$4.00	\$0.00	\$521.50	
Equipment:		CB801 - Circuit Breaker 801					Eqmt Cls/Type:		Cbreaker / TNP1					
Location:		\TNP\Texas City (43)					Serial No:		3278423675434783455					
1/7/2008		2296 - 1	serv	sch		Major Maintenance triggered by 5 fault interrupts or 3 year schedule	Y	00:00	06:00	\$0.00	\$0.00	\$0.00	\$0.00	
2/7/2008		2315 - 1	serv	sch		Major Maintenance triggered by 5 fault interrupts or 3 year schedule	Y	00:00	00:00	\$0.00	\$0.00	\$0.00	\$0.00	
* Total for Eqmt:		CB801			WO Cnt:	2		00:00	06:00	\$0.00	\$0.00	\$0.00	\$0.00	
Equipment:		Chiller 1 - Chiller					Eqmt Cls/Type:		Chiller / CClv45					
Location:		\D2\B1\Roof (Roof)					Serial No:		C2478423987					
1/3/2008		2307 - 1	pm	sch		Chiller Annual Preventive Maintenance	Y	00:00	03:30	\$105.00	\$46.78	\$0.00	\$151.78	
* Total for Eqmt:		Chiller 1			WO Cnt:	1		00:00	03:30	\$105.00	\$46.78	\$0.00	\$151.78	
Equipment:		Chiller 2 - Chiller					Eqmt Cls/Type:		Chiller / CClv45					
Location:		\D2\B1\Roof (Roof)					Serial No:		C2363409					
1/21/2008		2308 - 1	pm	sch		chiller monthly pm	Y	00:00	06:00	\$260.00	\$24.00	\$0.00	\$284.00	
2/21/2008		2401 - 1	pm	sch		Chiller bi monthly pm	Y	00:00	15:00	\$405.00	\$8.00	\$0.00	\$413.00	
4/21/2008		2403 - 1	pm	sch		Chiller bi monthly pm	Y	00:00	03:30	\$105.00	\$8.00	\$0.00	\$113.00	
* Total for Eqmt:		Chiller 2			WO Cnt:	3		00:00	24:30	\$770.00	\$40.00	\$0.00	\$810.00	
Equipment:		Chiller 3					Eqmt Cls/Type:		Chiller / CClv45					
Location:		\D2\B2\Roof (46)					Serial No:							
1/28/2008		2309 - 1	pm	sch		chiller monthly pm	Y	00:00	04:00	\$120.00	\$24.00	\$0.00	\$144.00	
4/30/2008		2407 - 1	pm	sch		Chiller bi monthly pm	Y	00:00	15:00	\$120.00	\$8.00	\$0.00	\$128.00	
* Total for Eqmt:		Chiller 3			WO Cnt:	2		00:00	19:00	\$240.00	\$32.00	\$0.00	\$272.00	
Equipment:		Chiller 4					Eqmt Cls/Type:		Chiller / CClv45					
Location:		\D2\B2\Roof (46)					Serial No:							
1/3/2008		2310 - 1	pm	sch		Chiller Annual Preventive Maintenance	Y	00:00	03:00	\$90.00	\$46.78	\$0.00	\$136.78	